

## REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

### Certificate

No. 2603

DATE 16/07/24

It is certified that an inspection team headed by— **Mr. Sanjay Kumar Paswan** (A.R.O) from **P. H. Division Bhagalpur East. Bhagalpur** inspected the **Redwood International School, NH-80 Near Petrol Pump, Mathurapur (Shivnarayanpur) Kahalgaon, Bhagalpur (Bihar)** on **13.07.2024** and found the **Redwood International School, NH-80 Near Petrol Pump, Mathurapur (Shivnarayanpur) Kahalgaon, Bhagalpur (Bihar)** has safe drinking water facilities for the **students** and members of staff institution and is maintaining the hygienic sanitation condition in the school campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of- **One Year (15.07.2024 to 14.07.2025)**.

Sanjay Kumar  
Signature With Seal: 15/07/24  
Name \_\_\_\_\_  
Designation \_\_\_\_\_

To,  
**Redwood International School**  
**NH-80 Near Petrol Pump,**  
**Mathurapur (Shivnarayanpur)**  
**Kahalgaon, Bhagalpur (Bihar)**

*Sanjay  
15/07/24  
A.R.O*

# Regional Water Testing Laboratory

Public Health Engineering Department,

Bhagalpur

Ref.No. EE-2569 dt-13.07.2024  
Date of Sampling - 13.07.2024

Name of Agency :Redwood International School,Kahalgaon

Sample Collected By- School Staff  
Source of Sample - Ground water

## PYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Physico - Chemical and Bacteriological Parameters																	Remarks		
	Block	Panchayet	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F	As	Microbial
1					<b>Redwood International School</b> NH-80 Near Petrol Pump,Mathurapur (Shivnarayanpur),Kahalgaon Bhagalpur ( Bihar)	7.52	0.48	562.0	276.0	144.6	48.2	22.40	26.0	136.0	0.14	5.2	6.4	0.14	NT	Negative
					Desirable Limit*	6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-
					Permissible Limit* in absence of alternate source	NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**

Note:- Not Tested

Memo No....RL - 154

Date .... 15/07/2024  
Copy Forwarded To : 1. Executive Engineer, P.H.Division Bhagalpur East, for kind information and necessary action.

*Sharma*  
15/07/24  
Lab Incharge(A.R.O)